



FIRELAB

CERTIFICATE

This is to certify that the

PET Bottle and Nylon-6 Fishnet Building System

With steel mesh reinforced plaster

achieved a

Fire Resistance Rating (FRR)

of

FR120

(INTEGRITY, STABILITY and INSULATION)

When tested in accordance with

SANS 10177 - Part 2

Signed:

Report Number: FTA208

Agrément Ref. No: 59A2409 (AB/20/1113)

Valid: Nov 2015 - Oct 2020

(For details of the registered system, refer to Agrément Certificate)

Reg nr: 2005/087037/23 • Tel: + 2712 349 2929 • info@firelab.co.za

SA SAMARPAN FOUNDATION NPC

ERINVINE, 40 CANTERBURY DR, BISHOPSCOURT, CAPE TOWN • WWW.SAMARPANFOUNDATION.ORG

